East Central Railway

Office of the General Manager (Signal & Telecomm) ECR, Hajipur

Dated: 04, 12.2024

No. ECR-HQ0SnT (CCP)/2/2024 (Comp.no. 279039)

Sr.DSTEs/ DDU/DHN/DNR/SEE /SPJ, East Central Railway.

Sub: Re-issue the Maintenance Schedule of the item "Automatic Fire Detection & Alarm System for Signalling and Telecom Installations (RDSO/SPN/217/2021 Ver. 3.0)"..

Ref: RDSO letter no. No. STS/E/AFD&SS Vol. - V dated 21.10.2024

Please find enclosed herewith the above referred RDSO's tentative maintenance schedule of Automatic Fire Detection and Alarm System (AFDAS) for Signalling and Telecom Installations as per RDSO Spec. RDSO/SPN/217/2021 Ver. 3.0 is re-issued for the guidance.

In view of above divisions are requested to implement this maintenance schedule of AFDAS for S&T installations accordingly.

DA: As above.

(D.K.Chand) Dy.CSTE/Signal/HJP for GM (S&T)/ECR/HJP





Fax: 91-522-2452332 Mob. No. 9794863311 E-mail:dirsig3@rdso.railnet.gov.in

Room No. 206, II floor,
Signal Directorate, Annexie-I Building,
Manak Nagar, LUCKNOW – 226011

Government of India - Ministry of Railways Research Designs & Standards Organisation LUCKNOW – 226011

No. STS/E/AFD&SS Vol. – V

Date- 21.10.2024 **By E-mail**

सचिव (सिगनल) रलवे बोर्ड, रलभवन, नईदिल्ली,	Secretary/Signal, Railway Board, Rail Bhawan, New Delhi
प्रधानमुख्य सिगनल एव दूरसंचारअभियन्ता	P. C.S.T.E.
मध्य रेलवे, मुम्बईसी.एस.टी.– ४०० ००१	Central Rly., Mumbai, CST - 400001
पष्चिमरेलवे, चर्चगेट, मुम्बई— ४०० ०२०	Western Rly, Churchgate, Mumbai - 400020
पूर्वरेलवे, फेयरलीप्लेस, कोलकाता— 700 001	Eastern Rly., Fairlie Place, Kolkata 700001
दक्षिणपूर्वरेलवे, गार्डनरीच, कोलकाता— 700 043	South Eastern Rly., Garden Reach, Kolkata - 700043
उत्तररेलवे, बड़ौदाहाउस, नईदिल्ली– 110 001	Northern Rly. Baroda House, New Delhi- 110001
पूर्वोत्तररेलवे, गोरखपुर— 273 012	North Eastern Rly., Gorakhpur- 273012
पूर्वोत्तरसीमान्तरेलवे, मालीगांव, गुवाहाटी— 781 011	North East Frontier Rly., Maligaon, Guwahati - 781011
दक्षिणरेलवे, पार्कटाउन, चेन्नई— 600 003	Southern Rly. Park Town, Chennai - 600003
दक्षिण मध्य रेलवे, सिकन्द्राबाद—500 371	South Central Rly., Secunderabad – 500371
पूर्व मध्य रेलवे, हाजीपुर।	East Central Railway, Hajipur.
पूर्वतटीय रेलवे, बी–1, रेलविहार,	East Coast Railway, B-1, Rail Vihar, Chandrasekharpur,
चन्द्रषेखरपुर, भुवनेष्वर-751023	Bhubneshwar - 751023
उ०म० रेलवे, "गंगा"परिसर, सुबेदारगंज, इलाहाबाद	N.C.Railway, Ganga Parisar, Subedarganj, Allahabad
उत्तरपष्चिमरेलवे, जयपुर—300206	North Western Railway, Jaipur - 300206
दक्षिणपष्चिमरेलवे, क्लबरोड, केषवपुर, हुबली—23	South Western Railway, Club Road, Keshavapur, Hubli
पष्चिम मध्य रेलवे, ओ०एस०डी० कार्यालय, जबलपुर	West Central Railway, OSD Office, Jabalpur
दक्षिणपूर्वोमध्य रेलवे, आर०ई० ऑफिसकाम्पलेक्स,	South East Central Railway, R.E. Office Complex,
बिलासपुर- 495004	Bilaspur - 495004
कोर , नवाब युसुफअलीरोड, सिविललाईन्स,	CORE, Nawab Yusuf Ali Road, Civil Lines,
इलाहाबाद— 211 001	Allahabad- 211001.
डी.एम.आर.सी., मेट्रोभवन, फायरब्रिगेडलेन,	Delhi Metro Rail Corporation Ltd., Metro Bhawan, Fire
बाराखम्भारोड, नई दिल्ली—110001	Brigade Lane, Barakhamba Road, New Delhi-110001
निदेषकईरिसेट, तारनाकारोडलल्लागुडा,	The Director/IRISET, Tarnaka Road, Lallaguda (P.O.),
पो0ओ० सिकन्दराबाद	Secunderabad-500017

Subject: Re-issue the Maintenance Schedule of the item "Automatic Fire Detection & Alarm System for Signalling and Telecom Installations (RDSO/SPN/217/2021 Ver. 3.0)".

The tentative maintenance schedule of **Automatic Fire Detection and Alarm System (AFDAS)** as Per RDSO Spec. RDSO/SPN/217/2021 Ver. 3.0 is reissued for the guidance to zonal railways.

DA: As Above

YOGENDRA PRATAP SINGH Digitally signed by YOCENDRA PRATAP SINGH DIX:—RIM -= ODUTH CENTRAL RAILWAY, ou=GOVERNMENT, 25.4.20=00b91 SIZ2796.2796.1036.063625da275de d39213f2a57ff162fc23fbc3d106a9f, postaCode=515801, st=ANDHRA PRADESH, postaCode=515801, st=ANDH

(Y P Singh)
Director/Sig-III
For DG/S&T

File No.RDSO-SIG0AFDS(AFDM)/1/2020-O/o JOHNTEDIRECTOR/SIGNALF3/RDSO 3183579/2024/O/o JOHNT DIRECTOR/SIGNAL SO Research Designs & Standards Organization

रेल अग्रद्त Transforming Railways

Phone: Off - 91-522-2465749

Rly: Off - 42391 Fax: 91-522-2452332

e-mail: dirsig3rdso@gmail.com,

dirsig3@rdso.railnet.gov.in

Mobile: 9794863311

No. STS/E/AFD&SS Vol. - V

LUCKNOW - 226011 Room No. 206, II floor, Signal Directorate, Annexe-I Building, Manak Nagar, LUCKNOW - 226011

Date: 29.09.2022

प्रमुख मुख्य संकेत एवं दूरसंचार अभियन्ता,	Principal Chief Signal & Telecom Engineer,	
मध्य रेलवे, मुम्बई सी.एस.टी ४००००१	Central Railway, Mumbai CST-400 001	
पश्चिम रेलवे, चर्चगेट, मुम्बई- ४०००२०	Western Railway, Churchgate, Mumbai – 400 020	
पूर्व रेलवे, फेयरली प्लेस, कोलकाता- ७००००१	Eastern Railway, Fairlie Place, Kolkata – 700 001	
दक्षिण पूर्व रेलवे, गार्डनरीच, कोलकाता-४३	South Eastern Rly., Garden Reach, Kolkata – 43	
उत्तर रेलवे, बड़ौदा हाउस, नई दिल्ली- ०१	Northern Railway, Baroda House, New Delhi- 01	
पूर्वोत्तर रेलवे, गोरखपुर- २७३०१२	Northeastern Railway, Gorakhpur -273 012	
पूर्वोत्तर सीमान्त रेलवे, मालीगांव, गुवाहाटी-११	North Frontier Railway, Maligaon, Guwahati- 781 011	
दक्षिण रेलवे, पार्क टाउन, चेन्नई- ६०० ००३	Southern Railway, Park Town, Chennai -600 003	
दक्षिण मध्य रेलवे, सिकन्दराबाद - ५०० ३७१	South Central Railway, Rail Nilayam, Secunderabad-71	
पूर्व मध्य रेलवे, हाजीपुर - ८४४१०१	East Central Railway, Hazipur-844101	
उत्तर पश्चिम रेलवे, जयपुर-३००२०६	North Western Railway, Jaipur-300206	
पूर्वतटीय रेलवे, ग्राउन्डतल, उत्तरी ब्लाक, समन्तविहार,	East Coast Railway, Rail Vihar, Ground floor, North	
भुवनेश्वर-१७	Block, Samant Vihar, Bhubneshwar -17	
उत्तर मध्य रेलवे, गंगा काम्पलेक्स, सूबेदारगंज, इलाहाबाद -	North Central Railway, Ganga Complex, Subedarganj,	
२११०१२	Allahabad- 211012	
दक्षिण पश्चिम रेलवे, क्लब रोड, केशवपुर, हुबली-५८००२३	South Western Railway, Club Road, Keshavpur, Hubli-23	
पश्चिम मध्य रेलवे, जबलपुर - ४८२००१	West Central Railway, 2 nd floor, DRM Office, Jabalpur-	
	482001	
दक्षिण पूर्वोमध्य रेलवे, आर०ई० ऑफिस काम्पलेक्स, बिलासपुर-	¥ .	
8€5008	Bilaspur-495004	
मैद्रो रेलवे, ३३/१, जवाहर लाल नेहरू रोड, कोलकाता- ७००		
009	700071	
कोर, नवाब युसुफ रोड सिविल लाइन्स इलाहाबाद- २११ ००१	CORE, Nawab Yusuf Road, Civil Lines, Allahabad- 211	
िनेशक क्रिकेट नामका केन नामका किलो	Discrete //DISET Townshee Book Lelle and B.O.	
निदेशक /इरिसेट, तारनाका रोड, लल्लागुडा, पीओ	,	
सिकन्दराबाद-१७	Secunderabad -17	

Maintenance Schedule of the item "Automatic Fire Detection & Alarm System Sub: for Signalling and Telecom Installations (RDSO/SPN/217/2021 Ver. 3.0)".

A tentative Maintenance schedule of the item "Automatic Fire Detection & Alarm System for Signalling and Telecom Installations has been approved by the competent authority and the same is attached here with for the use of zonal railways.

This is for kind information please.

(A.K.Yadav) Director/Signal-III For Director General/Signal

DA: As above.

Copy – As per list (Annx.-I) attached

Digitally Signed by Avadhesh Kumar Yadav Date: 29-09-2022 13:03:58

Reason: Approved

Annx.-I

1.	The Secretary (Signal) Railway Road	rd, New Delhi- 110001: for kind information please.	
2.	Executive Director (Tele Dev), Railway Board, New Delhi-110001: for kind information please.		
3.	Executive Director/Telecom /RDSO/Lucknow- 226 011.		
4.	कार्यकारी निदेशक/क्यू०ए०/एस० एण्ड Executive Director/QA/S&T/RDSO, 4th Floor, Annexe-II		
''	टी०/अ०अ०मा०सं०, लखनऊ- २२६०११	Abhikalp Bhavan, Manak Nagar Lucknow-226011.	
5.	कार्यकारी निदेशक /क्यू०ए० /एस० एण्ड	Executive Director/QA/S&T/RDSO, 1st Floor, IRCOT	
	टी०/अ०अ०मा०सं०, नई दिल्ली- ११०००१	Building, Shivaji Bridge, New Delhi-110001.	
6.	निदेशक /क्यू०ए० /एस०एण्डटी० /अ०अ०मा०सं०,	Director/QA/S&T/RDSO, 1st Floor, New Annexe Building,	
	मुम्बई- ४०००२०	Western Railway, Church gate, Mumbai-400 020	
7.	निदेशक /क्यू०ए० /एस०एण्डटी० /अ०अ०मा०सं०,	Director/QA/S&T/RDSO, Ground Floor, DRM Office,	
	बैंगलोर- ५६००२३	South western Railway, Bangalore - 560 023	
8.	निदेशक/क्यू०ए०/एस०एण्डटी०/अ०अ०मा०सं०,	Director/QA/S&T/RDSO, 4th Floor, 17 N.S Road West	
	फेयरली प्लेस, कोलकाता - ७००००१	Wing, Fairlie Place, Kolkata- 700 001	
9.	निदेशक/क्यू०ए०/एस०एण्डटी०/अ०अ०मा०सं०,	Director/QA/S&T/RDSO, Hasanpura Road, In Front of Railway	
	जयपुर- ३०२००६	Hospital Jaipur-302006	
10.		Ltd, Belapur Bhavan, Sector-II, CBD, Belapur, New Mumbai	
	-00614		
11.		oor, Delhi Metro Station Building, PragatiMaidan, New Delhi-	
12	110001	2/10 Seffering Development and Applied Men New	
12.	The CSTE, Rail Vikas Nigam Ltd., C-2/10, Safdarjung Development area, Aurobindo Marg, New Delhi – 110016		
13.		arnoration II floor Churchaste station building Mumbai	
15.	The CSTE, Mumbai Rail Vikas Corporation, II floor, Churchgate station building, Mumbai 400020		
14.			
	Floor, Amrit House, Sant Nagar, New Delhi-110065. E mail-		
	india.communications@honeywell.com, sheel. kumar@ honeywell.com		
15.			
	Nadu- 600096. E mail- <u>prabhu@ravelfire.com</u> , sales@ ravelfire.com		
16.			
	Maharashtra-411030 E mail- Sales@ Vighnaharta.in, jgirme@ Vighnaharta.in		
17.	M/s NOTOFIRE PVT. LTD., C-146, Ground Floor, Block C, Sector 63, NOIDA, Gautam		
	Buddha Nagar, Uttar Pradesh, India – 201301, Phone no. 09999991525, Email –		
4 -	indianotofire@gmail.com		
18.	M/s Advance HI-Tech, 1765-MIE, Part B, Bahadurgarh- Haryana -12407, Phone no.		
	09891823666 Email – aniljindal.sig@gmail.com		

(A.K.Yadav) Director/Signal-III For Director General/Signal

File No.RDSO-SIG0AFDS(AFDM)/1/2020-O/o JOINT DIRECTOR/SIGNAL-3/RDSO

3183579/2022/0955JORNT BIRLECTOR/SIGNVA (1937R 2959) 2022 SIG-301

Document Title: Maintenance schedule of Automatic Fire Detection and Alarm System for Signaling and Telecom installations.

SIGNAL & TELECOM DIRECTORATE **RESEARCH DESIGNS AND STANDARDS ORGANISATION MANAK NAGAR, LUCKNOW-226011**

Tentative

Title: Maintenance Schedule of Automatic Fire Detection and Alarm System for Signaling and Telecom installations.

(Spec. no. RDSO/SPN/217/2021 Ver. 3.0)

S. no.	Issue	Version	Reason of Amendment
1	First	0.0	

Prepared by:	Approved by:
V.K. Nayak SSE/Signal S.K. Srivastava ADE/Signal-V A.K. Yadav Director/Signal-III	Rajendra Dhambel PED/S&T

Document Title: Maintenance schedule of Automatic Fire Detection and Alarm System for Signaling and Telecom installations.

A. Automatic Fire detection & Alarm System for Signaling and Telecom Installation (Spec. no. RDSO/SPN/217/2021 Ver. 3.0)

The system consists of following major Sub-systems-

- 1. Probe Type BI-METALLIC HEAT DETECTOR for DG Enclosure.
- 2. UV and IR FLAME DETECTORS for DISEL OIL STORAGE ROOM.
- 3. HEAT & SMOKE MULTI SENSOR for Various Rooms (PowerEgpt., Battery, ASM, DG & Non –Air Conditioned Relay).
- 4. ASPIRATING (AIR SAMPLING) TYPE SMOKE DETECTOR for Air Conditioned Relay Room.
- 5. LHS CABLE & its INTERFACE MODULE or
- 6. LHD & its INTERFACE MODULE.
- 7. FIRE SURVIVAL CIRCUIT INTEGRITY CABLES.
- 8. CONTROL PANEL.
- 9. MANUAL CALL POINTS for Every Entry & Exit point of various rooms.
- 10. AUDIO VISUAL ALARM (HOOTER and STROBE).
- 11. PIPING.
- 12. BATTERY.

Name and Designation	Signature with date
	- 0

File No.RDSO-SIG0AFDS(AFDM)/1/2020-O/o JQINT DIRECTOR/SIGNAL-3/RDSO

3183579/202290965JOHVT: PARIE 201 OR / STICSNYA (1/23)/R 2022 SIG-301 Version- 0.1

Document Title: Maintenance schedule of Automatic Fire Detection and Alarm System for Signaling and Telecom installations.

B. Maintenance Schedule -

1. Fortnightly Schedule-

SN	Check the followings	Observations	Remarks if any
1	Date & Time of System at Control Panel		
2	Visual Indications on		
а	Control Panel (Power on LED)		
b	Manual Call Points		
С	Detectors		
d	Other devices		
е	Each device in the loop.(LED Blinking)		
3	Check internal Buzzer(Disconnect Primary Power).		
а	Mains fail indication at C/Panel		
b	Mains fail LED lit at C/Panel		
С	Internal Buzzer starts		
d	Restore Power Supply. Control Panel will get normalized.		
4	Press Menu on Control panel and see the conditions of device. (Failed, Fault, Fire & Disablement logs)		
а	Clean the particular detector in Fault		
b	Attend the fault (Detector missing, Disablement, Earth Fault, Low / No Battery Voltage, Mains Power Failure, Earth Fault, Sounder / Strobe Fault)-(Refer User manual /Troubleshooting Guide)		
5	Clean 25% of the detectors (Clean Different detectors in each schedule)		
6	Test at least 25% of the detectors (Test different detectors in each schedule- as per user manual)		

Name and Designation	Signature with date

File No.RDSO-SIG0AFDS(AFDM)/1/2020-O/o JOINT DIRECTOR/SIGNAL-3/RDSO 3183579/2024/6/65JOINT DIRECTOR/SIGNAL-3/RDSO SIG-301 Version 0.0

Document Title: Maintenance schedule of Automatic Fire Detection and Alarm System for Signaling and Telecom installations.

2. Monthly Schedule-

SN	Check the followings	Observations	Remarks if any
1	Measure Supply Voltage		
а	Main Supply Voltage to System (230 / 110V AC-should be +10% and -15%)		
b	SMPS O/P at Control Panel (24-27V DC)		
С	Stand by Battery Voltage (24-26V DC)		
d	Loop IN & Loop OUT Voltage(24-26V DC)		
2	Self-test- On control Panel (CP) go in Level II select self-test Mode.		
a	All LEDs on Control Panel (CP) lit		
b	Internal Buzzer will sound		
С	Panel Display get Blank		
d	After 2-3 sec. CP Restored to normal working condition.		
3	Remove any detector from the loop (Chec it's address and location displays on CP)		
4	Find me -On CP go in Level III select.		
a.	Select individual device address & check status of LED changes on device.		
b	If any device is not lit then check loop wiring connection/fitting/voltage		
5	Manual Call Point(MCP)-		
а	Press the button and see audio and visual indication on Control panel (CP). CP shows address & location of MCPs. The sounder sounds (if not check supply on terminal), mute it.		
b	Check the Sounder/Strobe activated at every location		
С	Reset The MCP using Reset Key. Also reset the CP		
5	Clean 25% of the detectors (Clean Different detectors in each schedule)		
6	Test at least 25% of the detectors (Test different detectors in each schedule- as per user manual)		

Name and Designation	Signature with date

File No.RDSO-SIG0AFDS(AFDM)/1/2020-O/o JOINT DIRECTOR/SIGNAL-3/RDSO 3183579/2024/5/15 JOHNT: PHRIECTOR/SIGNAL-3/RDSO SIG-301 Version 0.0

Document Title: Maintenance schedule of Automatic Fire Detection and Alarm System for Signaling and Telecom installations.

3. Quarterly Schedule -

Check the followings	Observations	Remarks if any
Clean the detectors& devices connected in		
AFDAS.		
Ensure that stable primary & secondary		
1 11 1		
Ensure proper fitting of detector/Devices.		
Check the complete system wiring.		
Ensure the Panel is displaying correct device		
name & address.		
Check Voltages Level		
Main Supply Voltage to System(230/110V		
AC)		
SMPS O/P at Control Panel(24-27V DC)		
Stand by Battery Voltage (24-26V DC)		
Lop IN and Loop OUT Voltage(24-26V DC)		
Clean 25% of the detectors (Clean Different		
detectors in each schedule) Note: Ensure that		
A		
· · · · · · · · · · · · · · · · · · ·		
*		
,		
` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` ` `		
1		
· · · · · · · · · · · · · · · · · · ·		
*		
	Clean the detectors& devices connected in AFDAS. Ensure that stable primary & secondary power supply is available to AFDAS. Ensure proper fitting of detector/Devices. Check the complete system wiring. Ensure the Panel is displaying correct device name & address. Observe the Visual indication & message on CP. Check Voltages Level Main Supply Voltage to System(230/110V AC) SMPS O/P at Control Panel(24-27V DC) Stand by Battery Voltage (24-26V DC) Lop IN and Loop OUT Voltage(24-26V DC) Clean 25% of the detectors (Clean Different	Clean the detectors& devices connected in AFDAS. Ensure that stable primary & secondary power supply is available to AFDAS. Ensure proper fitting of detector/Devices. Check the complete system wiring. Ensure the Panel is displaying correct device name & address. Observe the Visual indication & message on CP. Check Voltages Level Main Supply Voltage to System(230/110V AC) SMPS O/P at Control Panel(24-27V DC) Stand by Battery Voltage (24-26V DC) Lop IN and Loop OUT Voltage(24-26V DC) Clean 25% of the detectors (Clean Different detectors in each schedule) Note: Ensure that all the detectors have been cleaned at least once in a quarter. Test at least 25% of the detectors (Test different detectors in each schedule- as per user manual) Note: Ensure that all the detectors have been tested at least once in a quarter. Simulate fire like situation (use standard device or other means as per user manual)Perform the fire test in safe & controlled manner to check healthy condition of all loop devices. Reset the system after Fire test & ensure that

Name and Designation	Signature with date